C98279

CITY OF HAMMOND DIVISION OF CODE ENFORCEMENT

STATE OF INDIANA)	Case No. 83-015
OOUNTY OF LAKE)	Address: 4246 Torrence
CITY OF HAMMOND,	
Petitioner)	Date:2/17/83
vs)	
Edward J. Przybl) 3919 Johnson) Hammond, IN 46327)	RESCISSION OF ORDER TO COMPLY
Respondent(s))	

You are hereby notified, pursuant to I.C. 36-7-9-6, that the Order of the Division of Code Enforcement has been rescinded concerning the following property:

Frank Betz 3rd Add. L. 23 Bl. 2, commonly known as 4246 Torrence

By that Order you were to repair the property , as set forth in a List of Code Violations dated 12/22/82 a copy of which is attached.

If you have any questions you should contact the Division of Code Indiana Office. We would like to thank you for your cooperation.

JACQUELYN M. KOHL, DIRECTOR Division of Code Enforcement

City of Hammond, Indiana

Dated: 2/18/83

am

CITY OF HANDIOND, INDIANA DIVISION OF CODE ENFORCEMENT

CITY OF HAMMOND)				
Petitioner	No. 82-157			
}	ORDER TO COMPLY AND NOTICE			
vs	To Repair or Demolish			
Edward J. Przybl 3919 Johnson	Re: 4246 Torrence			
Hammond, IN 46327	Key 			
Respondent(s)	•			
TO:	Date: December 22, 1982			
Pursuant to I.C.	36-7-9, you must repair those items noted on the			
	ding code violations concerning the premises located			
at 4246 Torrence Av				
following legal descr				
•				
Frank Betz Sra Adaltic	on Lot 23, Block 2, commonly known as 4246 Torrence Ave.			
•				
These items must	be completely repaired by the 27th day of January			
19 83 .				
A hearing regard	ing this order will be held in Room 209 of the Hammond			
City Hall, located at	5925 Calumet Avenue, in the City of Hammond, County of			
	a, on the 27th day of January			
	o'clock P.M.			
	to appear at the hearing of this cause with or without			
•	lso have the right to present evidence in your favor, to			
	g witnesses, and to present your views regarding this			
	2 Avenosses, min en bresent lom Arens referring mine			
particular matter.				

William A. Bowers Unsafe Building Officer

CITY OF HALMOND, INDIANA DIVISION OF CODE ENFORCEMENT

STATE OF INDIANA	}				•	
COUNTY OF LAKE	}					
CITY OF HAMMOND						
•						
Petitioner	{					
vs.	Ş	No	82-157	·		
Edward J. Przybl)					
Respondent(s)	}		,		•	

To Repair or Demolish

Rear Extension

1. No foundnation on rear estension
2. Space heater not ducted out safely

3. Electric boxes not covered properly

4. Entrance rotted above entry door

5. Threshold rotted out at entrance door

6. Water heater not ducted out properly

7. Eaves rotted out - need to be replaced

House up front

1. Heater not ducted out properly

Nickolas J. Korba Building Inspector