3

860681

CITY OF HAMMOND DIVISION OF CODE ENFORCEMENT

STATE OF INDIANA,)		Case No.: _	85-017
COUNTY OF LAKE,) SS:		Address:	6217 Jefferson
CITY OF HAMMOND,)	Date:	6-19-86
Petitioner,)		
vs)		
Herman Eriks, Jr. 3031 Lakeside Dr. Highland, IN 46322))) .))	RECISSION O	F ORDER TO COMPLY
Respondent(s))		RD C
You are hereby notified, pu	rsuant to I	.C. 36-7-9-6	, that the Order of
the Division of Code Enforceme	nt has been	rescinded c	oncerning the
	n Add. L. 1	2 Bl. 10. Co	ommonly known as
By that Order you were to r	epair and/o	r demolish t	he structure, as set
forth in a List of Code Violat	ions, Exhib	it A, dated	1-25-86 a copy of
which is attached.			
If you have any questions y	ou should c	ontact the C	ity of Hammond
Division of Code Enforcement.			
Dated: 6-25-86	Catherine Division o 5925 Calum Room 135	f Code Enfor et Avenue ndiana 46320	ncela, Hearing Officer cement

CITY OF HAMMOND, INDIANA DIVISION OF CODE ENFORCEMENT

	CITY OF HAMMOND) .			
	Petitioner)	No. 85-002		
January Butt)	ORDER TO COMPLY AND NOTICE		
	vs)	To Repair or Demolish		
Herman Eriks, 3019 101st Pl	·	Re: 6218 Jefferson		
Highland, IN	10323	Key # 33-159-12		
	Respondent(s)			
	TO:	Date: 1-25-85		
		u must repair those items noted on the		
		lations concerning the premises located		
	at 6218 Jefferson	, Hammond, Indiana, which has the		
	following legal description:			
	Franklin Add. L. 12. Bl. 10			
		·		
	Those items must be completed	y repaired by the 21st day of March		
·	19 85.	y Topic Tid 13 the Block City of Halen		
		r will be held in Room 209 of the Hammond		
	City Hall, located at 5925 Calumet Avenue, in the City of Hammond, County of			
	Lake, State of Indiana, on the 21st day of March,			
	19 85 , at 1:30 p.m. o'clock			
		the hearing of this cause with or without		
		right to present evidence in your favor, to		
		and to present your views regarding this		
	particular matter.			
	1200 a Barra			
		and the second s		

William A. Bowers Unsafe Building Officer F MICH

. .

CITY OF HAMMOND, INDIANA DIVISION OF CODE ENFORCEMENT

STATE OF INDIANA)
COUNTY OF LAKE	
CITY OF HAMMOND	
Petitioner))))
vs.) No. 85-002
Herman Eriks, Jr.	· ·
Respondent(s))

- 1. All bedrooms are to have doors & passage door knobs.
- 2. Place drywall behind paneling in bath.
- 3. Replace water damaged ceiling throughout.
- 4. Finish all floors as necessary.
- 5. Replace tile in kitchen.
- 6. Replace rotted floor in kitchen by sink.
- 7. Properly install water supply lines.
- 8. Place trap on laundry tub.
- 9. Place drip leg on hot water heater.
- 10. Extend pressure relief line on hot water heater.
- 11. Provide proper air space for hot water heater stack.
- 12. Replace floor in rear bath.
- 13. Replace broken toilet tank cover.
- 14. Rear addition of building pulling away from main section, place foundation under this section.
- 15. Put on new hot roof, and remove all old tar paper and insulation board.
- 16. All ceilings to have 5/8 drywall.
- 17. Bring electric up to code.
- 18. Replace missing heat defusers.
- 19. Properly replace rear window or cover.
- 20. Replace all siding.
- 21. Replace all rotted windows and properly install front door.

Garage

- 22. Replace all rotted sheating, shingles, and rotted materials throughout.
- 23. Replace siding.
- 24. Replace side wall rotted sheating.